



2021/2022
LEAD TESTING

RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: PG Chambers School
15 Halko Drive
Cedar Knolls, NJ 079810000

Laboratory Results

Sample Number	Sample Location	Collected By
1221-7208	15 Halko Drive - Hanover Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1221-7208	12/11/2021 8:39:00 AM Room 2 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-10	12/11/2021 9:06:00 AM Room 4 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-11	12/11/2021 9:10:00 AM Fountain By Kitchen	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-12	12/11/2021 9:12:00 AM Kitchen By Room 3 Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-13	12/11/2021 9:14:00 AM Room 3 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-14	12/11/2021 9:17:00 AM Room 5 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-15	12/11/2021 9:19:00 AM Room 7 Class Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-16	12/11/2021 9:22:00 AM Room 12 Class Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-17	12/11/2021 9:24:00 AM Room 13 Class Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-18	12/11/2021 9:27:00 AM Room 14 Class Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-19	12/11/2021 9:46:00 AM Left Fountain By Room 14	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-2	12/11/2021 8:42:00 AM Staff Café Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-20	12/11/2021 9:47:00 AM Right Fountain By Room 14	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-21	12/11/2021 9:51:00 AM Gross Motor Gym Kitchen Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	2.71 ug/l	15 ug/L	Std Method 3113B
1221-7208-22	12/11/2021 9:55:00 AM Phys Ed Kitchen	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, January 31, 2022

NJDEP Laboratory Certification # 14006

Page 1 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: PG Chambers School
15 Halko Drive
Cedar Knolls, NJ 079810000

Laboratory Results

Sample Number	Sample Location	Collected By
1221-7208	15 Halko Drive - Hanover Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1221-7208-23	12/11/2021 9:57:00 AM Waddlers Room Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	2.65 ug/l	15 ug/L	Std Method 3113B
1221-7208-24	12/11/2021 10:00:00 AM Kathy's Preschool Kitchen Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-25	12/11/2021 10:02:00 AM Kathy's Preschool Fountain	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-26	12/11/2021 10:06:00 AM Kathy's Therapy Room Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	5.45 ug/l	15 ug/L	Std Method 3113B
1221-7208-27	12/11/2021 10:09:00 AM Resource Room Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-28	12/11/2021 10:13:00 AM Nurses Treatment Room Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	5.46 ug/l	15 ug/L	Std Method 3113B
1221-7208-29	12/11/2021 10:16:00 AM Room 1 Class Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-3	12/11/2021 8:44:00 AM Music Room Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-30	12/11/2021 10:19:00 AM 2nd Floor Kitchen Sink	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-31	12/11/2021 10:24:00 AM Room 14 Bubbler	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-32	12/11/2021 10:28:00 AM Room 9 Bubbler	12/20/2021 10:36:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-4	12/11/2021 8:47:00 AM Speech Therapy Kitchen Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-5	12/11/2021 8:49:00 AM Room 8 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-6	12/11/2021 8:52:00 AM Room 9 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-7	12/11/2021 8:58:00 AM Room 10 Bubbler	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, January 31, 2022

NJDEP Laboratory Certification # 14006

Page 2 of 3



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: PG Chambers School
15 Halko Drive
Cedar Knolls, NJ 079810000

Laboratory Results

Sample Number	Sample Location	Collected By
1221-7208	15 Halko Drive - Hanover Twp	Richard, Hand

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1221-7208-8	12/11/2021 9:01:00 AM Room 11 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B
1221-7208-9	12/11/2021 9:03:00 AM Room 6 Class Sink	12/15/2021 8:44:00 AM	Lead (1st Draw)	< 2.00 ug/l	15 ug/L	Std Method 3113B

The parameters tested on this report PASSED NJ Drinking Water Standards.

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Ashley Shann, Laboratory Manager Designee

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Monday, January 31, 2022

NJDEP Laboratory Certification # 14006

Page 3 of 3